

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	ELFRI Srl
Address	Via Friuli 9, 33050 Gonars (Ud), Italy
Place of Production	ELFRI Srl Via Friuli 9, 33050 Gonars (Ud), Italy
Trade Name	S5, S59
Description	Electromagnetic fire door holders
Application	Marine/Offshore applications
Specified Standard	LR Test Specification No.1:2019 (ENV3 category) UNI EN 1155:2003/EC 1-2008
Ratings	Supply voltage: 24 VDC IP rating: IP65 (S5 type) and IP67 (S59 type) Maximum associated door mass: 160kg

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. LR2004324TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Andrei Petrov

Surveyor to Lloyd's Register EMEA
A member of the Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.